

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/14/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155667	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED 10/09/2014
NAME OF PROVIDER OR SUPPLIER OAK GROVE CHRISTIAN RETIREMENT VILLAGE			STREET ADDRESS, CITY, STATE, ZIP CODE 221 W DIVISION ST DEMOTTE, IN 46310		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 10/09/14</p> <p>Facility Number: 010823 Provider Number: 155667 AIM Number: 200236630</p> <p>Surveyor: Bridget Brown, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Oak Grove Christian Retirement Village was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire, the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The original building identified as the Shepard's Care and Skilled units was located on the southeast and southwest wings of the first floor, built prior to March 1, 2003, and surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>The facility is located on the first floor of a two story fully sprinklered building of Type V (111) construction. The facility has a fire alarm system with hard wired smoke detection in the corridors, resident rooms and spaces open to the corridors. The facility has the capacity for 59 and had a census of 57 at the time of this survey.</p> <p>All areas where the residents have customary access and areas providing facility services were</p>	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/14/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155667	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED 10/09/2014
NAME OF PROVIDER OR SUPPLIER OAK GROVE CHRISTIAN RETIREMENT VILLAGE			STREET ADDRESS, CITY, STATE, ZIP CODE 221 W DIVISION ST DEMOTTE, IN 46310		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 sprinklered.	K 000			
K 000	<p>Quality Review by Dennis Austill, Life Safety Code Specialist on 10/10/14.</p> <p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 10/09/14</p> <p>Facility Number: 010823 Provider Number: 155667 AIM Number: 200236630</p> <p>Surveyor: Bridget Brown, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Oak Grove Christian Retirement Village was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire, the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The 2013 Oak Leaf Rehabilitation Unit was surveyed with Chapter 18, New Health Care Occupancies.</p> <p>The Oak Leaf Unit is a one story fully sprinklered building of Type V (111) construction. The addition has a fire alarm system with hard wired smoke detection in the resident rooms and in the corridor at the horizontal exit. The facility has the capacity for 59 and had a census of 49 at the time of this survey.</p>	K 000			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/14/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155667	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED 10/09/2014
NAME OF PROVIDER OR SUPPLIER OAK GROVE CHRISTIAN RETIREMENT VILLAGE			STREET ADDRESS, CITY, STATE, ZIP CODE 221 W DIVISION ST DEMOTTE, IN 46310		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 2 All areas where the residents have customary access and areas providing facility services were sprinklered. Quality Review by Dennis Austill, Life Safety Code Specialist on 10/10/14.	K 000			